



Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 264

Dated: 05/08/26

It is certified that an inspection team headed by Mr. DEVENDRA SINGH GROUND

(Name of Officers with designation) from Assistant Engineer.....PHED

inspected the ST. JOSEPH SR. SEC. SCHOOL NARSINGHPUR

(Name & Address of the school) on 03/08/26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 64 dated 05/08/26

of PHE NARSINGHPUR (PHED Lab) certified that

the ST. JOSEPH SR. SEC. SCHOOL Ngl (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 1 Year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : PHE. Sub.

To

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

SUB DIVISION WATER TESTING LABORATORY NARSINGHGARH
PUBLIC HEALTH ENGINEERING DEPARTMENT
NEAR SURAJPOOL, TEHSIL ROAD NARSINGHGARH 465669
Email: - aepghedngh@gmail.com



TEST REPORT				
Lab Reference Letter - SDWTL/PHED/NARSINGHGARH				
Type Of sample :- Drinking Water				
SENDER'S NAME :- ST.JOSEPH SENIOR SECONDARY SCHOOL Narsinghgarh				
PARTICULARS OF SAMPLE :- 01				
SAMPLE NO.	BLOCK	City	LOCATION	SOURCE
1	Narsinghgarh	Narsinghgarh	School Campus	Tube Well
Date of Receipt :- 03-08-2026			Time of Receipt :- 11:30 PM	
Date of Analysis Started :- 03-08-2026			Date of Analysis Completed :- 04-08-2026	

NATURE OF STUDY – Test Results

Field: Testing Discipline: Chemical Group: Water Sub Group: Drinking Water

Details of parameters , their test methods, units and specifications as per BIS

No	Characteristics	Test Method	Unit	AS Per BIS - 10500:2012 & Amendment Feb.2021		Results				
				Requirement t (Desirable limit)	Permissible limit in the absence of Alternate source	1	2	3	4	5
1	Total Hardness as CaCO ₃	IS 3025: 2009	Part21	mg/l	200	600	62.4			
2	Calcium as Ca	IS 3025: 1991	Part40	mg/l	75	200	24.96			
3	Magnesium as Mg	APHA 23 rd Ed. 3500- Mg ⁺² B	Part46	mg/l	30	100	14.97			
4	Total Alkalinity as CaCO ₃	IS 3025: 1986	Part23	mg/l	200	600	79.2			
5	Chloride as Cl	IS 3025: 1988	Part32	mg/l	250	1000	98			
6	pH	IS 3025: 1983	Part11	pH scale	6.5-8.5	6.5-8.5	7.02			
7	Turbidity	IS 3025: 1984	Part10	NTU	1	5	1.0			
8	Total Dissolved Solids	IS 3025: 2013	Part14	mg/l	500	2000	362			
9	Colour	IS 3025: 1983	Part 4	Hazen Units	5	15	-			
10	Taste	IS 3025:	Part	-	Unobjectionabl e	Objectionable	Unobjectionabl e			
11	Odour	IS 3025: 2018	Part 5	-	Unobjectionabl e	Objectionable	Unobjectionabl e			

- Note:- 1. This report should not be produced partly of full without approval of signatory authority for legal purposes.
2. This recommended that acceptable limit is to be implemented .Values in excess of those mentioned under "acceptable "render the water not suitable still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible limit in the absence of alternate source "above which the source will have to be rejected.
3. The results refer only to tested samples and parameters tested.
4. Sample will be stored for a period of 3 days from the date of issue of report.
5. This Lab does not hold any responsibility for variation in results for samples kept on hold for want of Clarification.

Remark:-

Reviewed by

(Ruchi Chauhan)
Quality Manager (Nabl)
Authorized Signatory

ISSUE NO. 65/SDWTL/PHED/NARSINGHGARH/2024-25 ISSUE DATE 05/08/26

SUB DIVISION WATER TESTING LABORATORY NARSINGHGARH**PUBLIC HEALTH ENGINEERING DEPARTMENT****NEAR SURAJPOOL, TEHSIL ROAD NARSINGHGARH 465669****Email: - aephedngh@gmail.com****TEST REPORT**

Lab Reference Letter - SDWTL/PHED/NARSINGHGARH				
Type Of sample :- Drinking Water				
SENDER'S NAME :- ST.JOSEPH SENIOR SECONDARY SCHOOL Narsinghgarh				
PARTICULARS OF SAMPLE :- 01				
SAMPLE NO.	BLOCK	City	LOCATION	SOURCE
1	Narsinghgarh	Narsinghgarh	School Campus	Tube Well
Date of Receipt :- 03-08-2026			Time of Receipt :- 11:30 PM	
Date of Analysis Started :- 03-08-2026			Date of Analysis Completed :- 04-08-2026	

NATURE OF STUDY – Test Results

Field: Testing

Discipline: Chemical

Group: Water

Sub Group: Drinking Water

Details of parameters , their test methods, units and specifications as per BIS

No	Characteristics	Unit	AS Per BIS - 10500:2012 & Amendment Feb.2021		Results				
			Requirement (Desirable limit)	Permissible limit in the absence of Alternate source	1	2	3	4	5
12	Temperature	°c	-	-	-				
13	Conductivity at 25°C	Micromhos Per cm°	-	-	-				
14	Nitrate as NO3	mg/l	45	45	0				
15	Iron	mg/l	1.0	1.0	0				
16	Fluoride as F	mg/l	1.0	1.5	0.32				
17	Sulphate as So4	mg/l	200	400	110.2				
18	Residual Chlorine as Cl2	mg/l	0.2	1.0	Nil				
19	Manganese as Mn	mg/l	0.1	0.3	-				
20	Arsenic	mg/l	0.01	0.01	-				
21	Total Coliform per 100 ml	mg/l	Nil		Negative				
22	Fecal Coliform 100 ml	mg/l	Nil		-				

Note: 1. This report should not be produced partly or full without approval of signatory authority for legal purposes.

2. This recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, still may be tolerated in the absence of an alternative source but up to the limits indicated under the "permissible limit in the absence of alternate source" above which the source will have to be rejected.


3. The results refer only to tested samples and parameters tested.

4. Sample will be stored for a period of 3 days from the date of issue of report.

5. This Lab does not hold any responsibility for variation in results for samples kept on hold for want of Clarification.

Remark :-

Reviewed by


ChemistSub Divisional Water Testing Laboratory
P.H.E.D. Sub division Narsinghgarh.
Assistant Engineer
PHE Sub Division Narsinghgarh
Sub Division Narsinghgarh_____
End of Report